
Using an External Voltage Regulator with a ZENA™ power generator



NOTE:

For 24 volt charging, replace WAI35-500-1 external 14V regulator with WAI35-503 external 24V regulator. Both 14V and 24V regulators may be used in circuit where dual voltage charging is desired, with appropriate switching. To do this, the Gnd/Return line may be common between both units and unswitched. All other connections (V in and + and - outputs) must be switched together using either a relay or an appropriate multi pole switch (which is rated at at least 10A per contact).